



American Samoa Power Authority

P.O. Box PPB
Pago Pago, American Samoa 96799
Telephone: (684) 699-3057
Email: bids@aspower.com
Website: www.aspower.com



ISSUANCE DATE: **June 23, 2022**
RFQ NO.: **RFQ No. ASPA22.035 Supply & Delivery of Wooden Power Poles**
SUBJECT: **Addendum No. 1**

The American Samoa Power Authority hereby issues Addendum No. 1 to amend Request for Quotations (RFQ) requirements. This addendum is issued pursuant to the conditions of the RFQ documents and is hereby made part of the RFQ. The addendum serves to clarify, revise, and supersede information contained in the RFQ. The Offeror must acknowledge receipt of this addendum in the appropriate space provided in the Addendum Form. Failure to do so may subject the Offeror to disqualification.

- 1. This second addendum provides a response to a query received for this solicitation. Attached at the end of this document is a clarification for Pole Suppliers.**

Should you have any questions or need clarification, please call me at (684) 699-3057 or procurement@aspower.com.

Sincerely,

Renee Leotele Togafau Mata'utia
Procurement Manager

Please sign and date below to acknowledge receiving Addendum 1. You may return this document via email at procurement@aspower.com, or the ASPA Procurement Office.

ACKNOWLEDGEMENT OF RECEIVING ADDENDUM 1

Received by _____, this _____ day of _____ 2022.
Company _____ Title _____
Fax No. _____ Email Address _____


REQUEST FOR INQUIRIES:

Question 1:

Is the Radiata pine from New Zealand acceptable for the power poles of this tender?

Answer 1:

For NZ pole suppliers, the following treatment is acceptable as a minimum:

 H5	Exposed to the weather, in ground or in fresh water	Ground contact, conditions of severe or continuous wetting, where uses are critical, where a higher level of protection than H4 is required	Decay	Copper Chromium arsenic (CCA)	House piles
			Fungi		Poles
			Borer	Alkaline Copper Quaternary (ACQ)	Crib walling
			Marine Borer		Posts in ground for decks, verandas, pergolas