



American Samoa Power Authority

P.O Box PPB • Pago Pago, American Samoa 96799

Phone: (684) 248-1234

ISSUANCE DATE: August 4, 2017

RFP NO.: ASPA17.045.WTR

PROJECT: Upper Amouli Tank Replacement

SUBJECT: Addendum #1

The American Samoa Power Authority (ASPA) hereby issues Addendum #1 to amend Request for Proposal (RFP) requirements. This addendum is issued pursuant to the conditions of the RFP documents and is hereby made part of the RFP. The addendum serves to clarify, revise, and supersede information contained in the RFP. The Offeror must acknowledge receipt of this addendum in the appropriate space provided on the Addendum Form. Failure to do so may subject the Offeror to disqualification.

1. A **pre-proposal meeting** will be held on **August 17, 2017 @ 9:00 am American Samoa Time** at Materials Management Conference Room on the ASPA Tafuna Compound with a site visit to follow.
2. The **Closing Date** for this project has been extended from Thursday, August 17, 2017 to **Tuesday, August 29, 2017 at 2:00 p.m. American Samoa Time.**
3. Please find questions below from potential Offerors (Q) and answers from ASPA (A):

Q-1. I would like to verify if all the pipes, fitting and other appurtenances will be supply by ASPA?

A-1. The Contractor is responsible to provide all pipes, fittings and other appurtenances. Please refer to **Attachment B - Section B.1.4 Miscellaneous Pipework** of the RFP: "*Design, furnish all supervision, labor, equipment, materials and services required for any piping works....*"

Q-2. Do you have specification for Temporary Tank 60,000 gallons?

A-2. The Contractor must provide a suitable temporary tank for temporary potable water storage and shall submit their recommendation to the project engineer for approval in their proposal and prior to procuring a temporary tank. Attachment J specifications is for a 320,000 gallon tank.

Q-3. On the cost proposal submission as per proposal invitation instruction #3 stated there an original and one (1) PDF copy while on IV-B of page 8 an original and one (1) copy of the proposal. Which instruction should we follow?

A-3. An Original and one (1) PDF copy of the proposal is required.

Q-4. Where is the location of temporary water storage tank?


A-4. Temporary tank will be located inside the project area shown on Site Plan Drawings. The Contractor is responsible for evaluating the most suitable on-site location for the temporary tank placement.

Q-5. Design for the road extension.

A-5. The Contractor is responsible for designing, and furnishing labor, equipment, services required for construction of the proposed concrete access way (Sheet 12 – C4 Dwg) and must include its costs in the Proposal Cost Form under B.1.1 Site Works.

Should you have any questions or need clarification, please call me at 248-1234.

Sincerely,



Ioana S. Uli
Procurement Manager
Procurement Office

Please sign and date below to acknowledge receiving Addendum 1. You may return this document via email to the ASPA Procurement Office at bids@aspower.com.

ACKNOWLEDGEMENT OF RECEIVING ADDENDUM 1

Received by _____, this _____ day of August, 2017

Company _____ Title _____

Fax No. _____ Email Address _____